



January 21, 2009

Mr. Ed Abbasi
Washington Department of Ecology
Northwest Regional Office
3190 160th Ave SE
Bellevue, Washington 98008

Re: Resubmittal - Sanitary Discharge Monitoring Report –November 2008
Seattle-Tacoma International Airport
NPDES Permit WA-002465-1, Part I Special Condition S5.D

Dear Mr. Abbasi:

Enclosed you will find the resubmitted Sanitary Discharge Monitoring Report for Cooling Tower Blowdown prepared in compliance with Part I Special Condition S5.D of the NPDES Permit for Seattle-Tacoma International Airport for November 2008.

The following information has been corrected from the previous submittal; average daily flow, monthly maximum flow and total flow.

If you have any questions regarding this letter, please contact Bob Duffner of my staff at 206/988-5528.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael D. Feldman". The signature is fluid and cursive, written over the printed name.

Michael D. Feldman
Deputy Managing Director, Aviation Division

Enclosure: DMR (4 pages)

Permittee Name/Address
 Include Name/Location (if different)

NAME SEA-TAC AIRPORT #681
 ADDRESS PORT OF SEATTLE
P.O. BOX 68727, SEATTLE 98168
 FACILITY SAME AS ABOVE
 LOCATION SAME AS ABOVE

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT(DMR)

WA0024651
 PERMIT NUMBER
 MTBD - Midway
 (POTW)
 DISCHARGE NUMBER


NOTE: Read instructions before
 completing this form.

MTBD

Discharge Location
Lat ° ' " N
Long ° ' " W
NO DISCHARGE

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 08	11	01		08	11	30

Parameter		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				No. of Exceed-ances	Frequency of Analysis	Sample Type
		Average	Maximum	Units	Minimum	Average	Maximum	Units			
FLOW-COOLING TOWER BLOWDOWN	Sample Measurement	2313	13220	GPD	*****	*****	*****	***	0	DAILY	MEAS.
	Permit Requirement	16000	250000		*****	*****	*****				
	Sample Measurement	*****	*****	***	*****	*****	*****	***			
	Permit Requirement	*****	*****		*****	*****	*****				
	Sample Measurement	*****	*****	***	*****	*****	*****	***			
	Permit Requirement	*****	*****		*****	*****	*****				
	Sample Measurement	*****	*****	***	*****	*****	*****	***			
	Permit Requirement	*****	*****		*****	*****	*****				
	Sample Measurement	*****	*****	***	*****	*****	*****	***			
	Permit Requirement	*****	*****		*****	*****	*****				
	Sample Measurement	*****	*****	***	*****	*****	*****	***			
	Permit Requirement	*****	*****		*****	*****	*****				
	Sample Measurement	*****	*****	***	*****	*****	*****	***			
	Permit Requirement	*****	*****		*****	*****	*****				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Michael D. Feldman Deputy Managing Director, Aviation Division TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
			(206) 439-7706 AREA NUMBER CODE	09/01/21 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 NA - Not Applicable, N/A - Not Analyzed
 69,412 gallons were discharged from the cooling tower blowdown during November 2008.