



EQUIPMENT TAGS:

- ① PANELBOARD - 208/120 V, 3 PHASE, 4W
- ② SWITCHGEAR PRIMARY MAIN DISCONNECT SWITCH, LOADBREAK RATED, FUSE TYPE.
- ③ MV TRANSFORMER, 12.47 KV DELTA - 480/277 V, WYE ENCLOSED, 60KVA.
- ④ EROSION CORRUPT BREAKER PROTECTOR - DISTRIBUTION TRANSFORMER PRIMARY.
- ⑤ CABLE TRAY
- ⑥ PRIMARY FEEDER CIRCUIT, GRC (SEE KEYED NOTE 36)

1. GROUNDING CONDUCTORS RUN ON BUILDING STEEL OR CONCRETE STRUCTURE SHALL BE SUPPORTED AT INTERVALS OF NOT MORE THAN 2'-6" HORIZONTALLY AND 4'-0" VERTICALLY.
2. COPPER ALLOY GROUNDING FITTINGS.

[illegible]