



NOTE:
PROVIDE SUFFICIENT SLACK IN ALL CONDUCTORS AND FLEXIBLE CONDUIT CROSSING EXPANSION JOINTS TO ALLOW FOR STRUCTURE EXPANTION/CONTRACTION. COORDINATE REQUIREMENTS WITH POS RESIDENT ENGINEER.

DESIGNED BY	DATE	DETAIL: STIA, F&I STANDARD DETAILS EXPANSION JOINT CONDUIT GROUNDING DETAIL
HGI	3/26/14	
DRAWN BY	DATE	
HGI	3/26/14	
CHECKED BY	DATE	
APPROVED BY	DATE	
<div><div>0</div></div>		REVISION: DESCRIPTION: STD: 260526
		04

