

DETAIL  
TYPICAL SWITCH VAULT  
EQUIPMENT LAYOUT  
SCALE: NTS


- GENERAL NOTES:**
1. IN GRASSY OR BARRED AREAS, VAULT LID TOP SHOULD BE 6" ABOVE GRADE. IN GRAVEL AREAS, VAULT LID TOP SHOULD BE 1" TO 2" ABOVE GRADE. WITH A TAPER DOWN TOWARDS THE SURROUNDING SURFACE.
  2. VAULT LID SHALL BE NO MORE THAN 1'-6" AFG IN FRONT OF EQUIP.
  3. THERE SHALL BE A MINIMUM OF 6' CLEARANCE IN FRONT OF SWITCHES AND SECTIONALIZERS.
  4. ALL DUCTBANKS SHALL ENTER AT THE EDGES OF A WALL AND ON THE SHORT WALL WHEN POSSIBLE.

**KEYED NOTES:**


① REFER TO THE FOLLOWING TABLE FOR EQUIPMENT USED

SECTIONALIZERS	Mfg	Part #	EQUIP.	OPENING LENGTH
2 POINT	Cooper	450L00K28A	5'-6"	4'-6"
3 POINT	Cooper	450L00K28A	5'-6"	4'-6"
4 POINT	Cooper	450L00K30A	6'-6"	5'-6"
PMI SWITCHES				
3-WAY	S & C	330	6'-0"	4'-0"
4-WAY	S & C	422	6'-0"	5'-0"
5-WAY	S & C	523	6'-6"	6'-7"
6-WAY	S & C	624	8'-6"	7'-10"


- ② BASE VAULT LENGTH = 6'-6"
- ③ ADD 1'-6" ON EITHER SIDE OF EQUIPMENT TO BASE VAULT LENGTH
- ④ ENGRAVE SWITCH VAULT NUMBER IN HATCH USING 5" MIN CHARACTERS



DETAIL  
DETAIL SHOWING VAULT LID  
AND SUMP ACCESS  
SCALE: NTS




DETAIL  
CABLE SUPPORT DETAIL  
SCALE: NTS



SECTION  
SWITCH VAULT SECTION  
SCALE: NTS

CALL 48 HOURS  
BEFORE YOU DIG  
1-800-424-5555



SECTION  
15KV PMI SWITCH SHOWING  
200A LB ELBOW TERMINATION  
SCALE: NTS

SECTION  
SECTIONALIZING CABINET SHOWING  
200A LB & 600A DB TERMINATIONS  
SCALE: NTS

DESIGNER: JAS		PROJECT ENGINEER: JAS		PROJECT: Port of Seattle SEA-TAC INTERNATIONAL AIRPORT		WORK ORDER NO. *	
CHECKED BY: JAS		DATE: 10-23-2002		SHEET TITLE: SWITCH VAULT DETAILS		CONSULTANT'S NO. 261349.01	
DESIGNED BY: JAS		DATE: 10-23-2002		PROJECT: ELECTRICAL INFRASTRUCTURE PROJECT TITLE		POINT OF ENTRY NO. STIA-XXXX-E002	
APPROVED BY: JAS		DATE: 10-23-2002		PROJECT: ELECTRICAL INFRASTRUCTURE PROJECT TITLE		POINT OF ENTRY NO. STIA-XXXX-E002	

\*CONSULTANT'S LOGO