



NOTES:

1. CABINET CONSTRUCTION: ANSI GRAY FINISH, 14 -12 GAUGE WITH "U.L." LABEL.
2. ALL NAME PLATES SHALL BE PHENOLIC WITH ADHESIVE BACK.
(SEE NAME PLATE SCHEDULE FOR DETAILS)
2. REFER TO SPECIFICATIONS FOR APPROVED MANUFACTURERS.

NAME PLATE SCHEDULE

ITEM NO	NAMEPLATE INSCRIPTION LINE 1 / LINE 2 / LINE 3 / LINE 4 / LINE 5	CHARACTER HEIGHT / BACKGROUND	REMARKS
1	PANEL B2 - E2 - 38G (OLD EX-15) / 225A 208Y/120V 3Ø 4WSN / FED FROM PANEL B2 - E2 - 30G/1, 3, 5	3/8" H WHITE CHAR. ON BLACK BACKGROUND	RED BACKGROUND FOR EMERGENCY POWER
2	VOLTAGE - 208Y/120V 3Ø 4WSN / AØ - BLACK / BØ - RED / CØ - BLUE / N - WHITE	3/16" H WHITE CHAR. ON BLACK BACKGROUND	
3	FOR PANEL ACCESS CALL / ACC: (206) 787-5406 OR / SHOP: (206) 787-5311	3/16" H WHITE CHAR. ON BLACK BACKGROUND	
4	WARNING - ANY UNAUTHORIZED USE OF / PANEL MAY RESULT IN SUSPENSION / OF PORT OF SEATTLE BADGE	1/2" H RED CHAR. ON WHITE BACKGROUND	5/8" H RED CHAR. FOR "WARNING" ONLY



DESIGNED BY	DATE
J. GO	10/24/01
DRAWN BY	DATE
J. GO	10/24/01
CHECKED BY	DATE
APPROVED BY	DATE

DETAIL:

STIA, F&I STANDARD DETAILS
PANEL TRIM
DOOR-IN-DOOR TYPE

REVISION:



DESCRIPTION:

STD: 262416

02