

GENERAL NOTES:

1. DATA CABLE SHALL BE SYSTIMAX CATEGORY-6 CABLES.
2. DATA CABLE INSTALLATION SHALL CONFORM TO ALL APPLICABLE REQUIREMENTS GIVEN IN CONSTRUCTION SPECIFICATION DIVISION 27.

KEYED NOTES

1. CONTRACTOR SHALL TERMINATE, CONNECT, AND ROUTE COMMUNICATIONS CABLING IN MINIMUM 1" CONDUIT. CONDUIT CABLE FILL SHALL COMPLY WITH 40% MAX FILL AS GIVEN IN TIA-569-C.
2. CONTRACTOR SHALL ROUTE DATA CABLING AND CONDUIT TO COMM ROOM AND TERMINATE CABLES ON PATCH PANEL.
3. PORT ET TO CROSS CONNECT. CONTACT MICAH EGGER (ET SHOP) AT 206-218-3787.
4. PORT PM TO SUBMIT REQUEST AT START MEETING FOR METER IP ADDRESS, DATA CABLE TAG NUMBER, PATCH PANEL PORT NUMBER AND COMM ROOM NUMBER.
5. DEPENDING ON METER CABINET CONFIGURATION, COPPER DATA CABLE MAY TERMINATE ON SWITCH IN METER CABINET WITH FIBER LEAVING METER CABINET AND RUNNING TO COMM ROOM.
6. PORT UTILITIES SHALL ASSIGN METER NUMBER AT INITIAL PEST MEETING.

