



- GENERAL NOTES:**
1. MINIMUM MANHOLE SIZE. NOT RECOMMENDED UNLESS PHYSICAL CONSTRAINTS DICTATE USE.
  2. TERMS-A-DUCTS RECOMMENDED FOR CONDUITS IDENTIFIED AT INSTALLATION OF MH.



**SECTION**

CABLE PULLING MANHOLE  
SCALE: 1/4" = 1'-0"

A	A
05	09



**PLAN**

CABLE PULLING MANHOLE  
SCALE: 1/4"=1'-0"

**REVISIONS**

NO.	DATE	BY	DESCRIPTION
1	03/01/19	KDM	2019 F&I STANDARD DETAILS

PROJECT MANAGER:

PROJECT ENGINEER:

DESIGN ENGINEER:

DRAFTER:

SCALE:  
AS NOTED

DATE:

CHECKED/APPROVED BY:



SEA-TAC INTERNATIONAL AIRPORT

PROJECT: F&I STANDARD DETAILS

SHEET TITLE: **CABLE PULLING MANHOLE  
PLAN AND SECTION**

WORK PROJECT NO.

CONSULTANT'S NO.

PORT OF SEATTLE NO.

260543

05