



DETAIL

PANEL TRIM
DOOR-IN-DOOR TYPE
SCALE: NONE

NOTES:

1. CABINET CONSTRUCTION: ANSI GRAY FINISH, 14 -12 GAUGE WITH "U.L." LABEL
2. ALL NAME PLATES SHALL BE PHENOLIC WITH ADHESIVE BACK.
(SEE NAMEPLATE SCHEDULE FOR DETAILS)
3. REFER TO SPECIFICATIONS FOR APPROVED MANUFACTURERS.

NAME PLATE SCHEDULE			
ITEM NO	NAMEPLATE INSCRIPTION LINE 1 / LINE 2 / LINE 3 / LINE 4 / LINE 5	CHARACTER HEIGHT / BACKGROUND	REMARKS
1	PANEL B2 - E2 - 38G (OLD EX-15) / 225A 208Y/120V 3Ø 4WSN / FED FROM PANEL B2 - E2 - 30G/1, 3, 5	3/8" H WHITE CHAR. ON BLACK BACKGROUND	RED BACKGROUND FOR EMERGENCY POWER
2	VOLTAGE - 208Y/120V 3Ø 4WSN / AØ - BLACK / BØ - RED / CØ - BLUE / N - WHITE	3/16" H WHITE CHAR. ON BLACK BACKGROUND	
3	FOR PANEL ACCESS CALL / ACC: (206) 787-5406 OR / SHOP: (206) 787-5311	3/16" H WHITE CHAR. ON BLACK BACKGROUND	
4	WARNING - ANY UNAUTHORIZED USE OF / PANEL MAY RESULT IN SUSPENSION / OF PORT OF SEATTLE BADGE	1/2" H RED CHAR. ON WHITE BACKGROUND	5/8" H RED CHAR. FOR "WARNING" ONLY

R E V I S I O N S				<div>PROJECT MANAGER: — PROJECT ENGINEER: — DESIGN ENGINEER: — DRAFTER: — SCALE: AS NOTED DATE: — CHECKED/APPROVED BY: —</div>		<div><div>Port of Seattle</div><div>SEA-TAC INTERNATIONAL AIRPORT</div><div>PROJECT: F&I STANDARD DETAILS</div><div>SHEET TITLE: PANEL TRIM DOOR-IN-DOOR TYPE</div></div>		WORK PROJECT NO.	
NO.	DATE	BY	DESCRIPTION					CONSULTANT'S NO.	
1	03/01/19	KDM	2019 F&I STANDARD DETAILS					PORT OF SEATTLE NO. 262416 02	