



Arc Flash and Shock Hazard
Appropriate PPE Required

1' - 6"	Flash Hazard Boundary
1.2	cal/cm2 Flash Hazard at 18.0 Inches
	PPE Level
	Refer to NFPA 70E-2018 Table 130.5(G)
12.47	kV Shock Hazard when cover is removed
5' - 0"	Limited Approach
2' - 2"	Restricted Approach - Class 2 Voltage Gloves
0' - 0"	Prohibited Approach - Class 2 Voltage Gloves

Equipment Name: [EQUIP NAME] (Fed by: [UPSTREAM EQUIP])
[CONSULTANT], 3/1/2019, POS: _____

R E V I S I O N S				<div>PROJECT MANAGER: —</div> <div>PROJECT ENGINEER: —</div> <div>DESIGN ENGINEER: —</div> <div>DRAFTER: —</div> <div>SCALE: NONE</div> <div>DATE: —</div> <div>CHECKED/APPROVED BY: —</div>	<div><div>Port of Seattle</div><div>SEA-TAC INTERNATIONAL AIRPORT</div><div>PROJECT: F&I STANDARD DETAILS</div><div>SHEET TITLE: ARC FLASH LABEL TEMPLATE</div></div>	WORK PROJECT NO.	
NO.	DATE	BY	DESCRIPTION			CONSULTANT'S NO.	
1	03/01/19	KDM	2019 F&I STANDARD DETAILS				
				PORT OF SEATTLE NO.			
				260573	01		