



**DETAIL**  
PROPER METHOD TO RACK  
HAMMERHEAD SEPARABLE SPLICES  
HALF SIZE SCALE: 3/4"=1'-0"



**DETAIL**  
CABLE RACK DETAIL  
HALF SIZE SCALE: 1 1/2"=1'-0"



**GENERAL NOTES:**

1. SEE GROUNDING, LABELING, AND RACK DETAILS FOR RELATED REQUIREMENTS.
2. SEE SPECIFICATION 260513 FOR SPLICE ASSEMBLY REQUIREMENTS.

RACK SPACING		
CABLE SIZE	"A" IN FEET	"B" IN FEET
2/0	4.5	3.0
4/0	4.0	3.0
350	3.0	3.0
500	2.5	2.5
750	2.0	2.0

TABLE VALUES APPLY TO 5KV AND  
15KV TYPE MV-105 CABLE ONLY

REVISIONS

NO.	DATE	BY	DESCRIPTION
1	03/01/19	KDM	2019 F&I STANDARD DETAILS

PROJECT MANAGER:  
—  
PROJECT ENGINEER:  
—  
DESIGN ENGINEER:  
—  
DRAFTER:  
—  
SCALE:  
AS NOTED  
DATE:  
—  
CHECKED/APPROVED BY:  
—



SEA-TAC INTERNATIONAL AIRPORT

PROJECT: F&I STANDARD DETAILS

SHEET TITLE: **PROPER SPLICE ORIENTATION  
AND CABLE RACK SPACING**

WORK PROJECT NO.

CONSULTANT'S NO.

PORT OF SEATTLE NO.

260513 02