



DETAIL
TERMINATION DETAIL FOR
COOPER SECTIONALIZING CABINET
SCALE: 3/4"=1'-0"



SECTION
600A ELBOW TERMINATION AT
SECTIONALIZING CABINET
SCALE: 3/4"=1'-0"



DETAIL
ONE-LINE DIAGRAM OF SECTIONALIZER
SCALE: N/A

- KEYED NOTES:**
- 1 REMOTE FAULT INDICATOR TO BE PLACED ON SIDE OF SECTIONALIZING CABINET OPPOSITE THE PMI SWITCH UNLESS DIRECTED OTHERWISE. SCHWEITZER PART NUMBER 3CRL-0800-IRACC OR APPROVED EQUAL. ADD 'W' TO PART NUMBER FOR TAMPER PROOF WINDOW KIT.
 - 2 XXX = SWITCH VAULT OR MANHOLE NUMBER
YYY = FEEDER NUMBER
 - 3 FASTEN CONTROL CABLES TO THE BACK OF THE ENCLOSURE WITH ADHESIVE TY-RAP ANCHORS AND TY-RAPS.
 - 4 MOUNT FAULT INDICATOR PER MANUFACTURERS RECOMMENDATIONS. REFINISH EXPOSED STEEL EDGES OF HOLES TO MATCH THE EXISTING FINISH.

R E V I S I O N S				<div><div><div>PROJECT MANAGER: —</div><div>PROJECT ENGINEER: —</div><div>DESIGN ENGINEER: —</div><div>DRAFTER: —</div><div>SCALE: AS NOTED</div><div>DATE: —</div><div>CHECKED/APPROVED BY: —</div></div><div><div><div>Port of Seattle</div><div>SEA-TAC INTERNATIONAL AIRPORT</div></div><div>PROJECT: F&I STANDARD DETAILS</div><div>SHEET TITLE: SECTIONALIZING CABINET DETAILS FAULT INDICATORS</div></div></div> <div><div>WORK PROJECT NO.</div><div>CONSULTANT'S NO.</div><div>PORT OF SEATTLE NO. 261800 02</div></div>
NO.	DATE	BY	DESCRIPTION	
1	03/01/2019	KDM	2019 F&I STANDARD DETAILS	
2	03/01/2020	KDM	2020 F&I STANDARD DETAILS	